

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A,3rd Street, S.S.Nagar. Palanipet,
Arakkonam – 631002

Off: 400, Nethaji Bose 4th Street
Phase III, TNHB, Sathuvachari
Vellore – 632 009

Cell: 9443106470, 8056631312
Email: dnatarajan8@gmail.com

Ref: Collector, VLR Lr. No. **ந.க.அ/31531/2013** Dated: 23.09.2015

STRUCTURAL SOUNDNESS CERTIFICATE RELATING TO PLAY SCHOOL
STATEMENT ACCOMPANYING FORM - A

1. Name of the Play School and Door no of the Building : **VANIYAMBADI GLOBAL SCHOOL**
D. No. 231/11, Nethaji Nagar, Amburpet Village,
Vaniyambadi Taluk, Tirupattur District - 635752
2. Location (street No. Ward No. Name of place, ie., Corporation, Municipality/ Panchayat Union/ Panchayat/Township/Cantonment) : S. F. Nos. 34/11 (P) & 34/10,
D. No. 231/11, Nethaji Nagar,
Amburpet Village, Vaniyambadi Town & Taluk,
Tirupattur District - 635752
3. Year of construction : **New Block I: Ground Floor: RCC: 2011; First Floor: RCC: 2014**
Toilet Block: Ground Floor: RCC: 2011
4. Approximates cost of construction as per current rate : Rs. 55.00 Lakhs
5. Purpose for which the building is being used or proposed to be used : Educational
6. Purpose for which the building has hitherto been used : Educational
7. Details of construction of the building (particulars of the foundation, soil, Specification of various parts under
(i) Foundation : RCC Column & Footing
(ii) Basement : RCC Column, Plinth Beam & Brick in CM
(iii) Superstructure : RCC Column & Brick in CM
(iv) Floor & Roof are to be given) : Flooring: Ceramic Tiles & Cement
Roof: RCC Slab
8. Period for which the license is require : **May be issued from 01.06.2022 to 31.05.2025**
(For Three years only)
9. Number of persons to be accommodated Refer "ANNEXURE" to this : **Five Hundred Eighty (580) Pupils only**

Place : Vellore

Date : 07.06.2022

Signature of the Correspondent

Signature of the Engineer

Er. D. NATARAJAN, B.E.,(CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore-632 009
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம்.



மழை பெறுவோம்

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A,3rd Street, S.S.Nagar. Palanipet,
Arakkonam - 631002
Off: 400, Nethaji Bose 4th Street
Phase III, TNHB, Sathuvachari
Vellore - 632 009
Cell: 9443106470, 8056631312
Email: dnatarajan8@gmail.com

FORM - B

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

VANIYAMBADI GLOBAL SCHOOL, AMBURPET VILLAGE, VANIYAMBADI

FORM OF CERTIFICATE OF STRUCTURAL SOUNDNESS UNDER SUB SECTION (B) OF SECTION OF (4) OF SECTION 4 OF THE TAMIL NADU PUBLIC BUILDING (LICENSING ACT 1965 TAMIL NADU ACT 1 OF 1965) REFERRED TO IN RULE OF THE TAMIL NADU PUBLIC (LICENSING) RULES 1966.

I Certify, that I have inspected the building mentioned in the statement and furnished below its salient technical features.

1. **Foundation:**

- | | | |
|------|--|-------------------|
| i. | Depth below ground level | : 04ft below G.L |
| ii. | Nature of soil met out in the foundation | : SDR |
| iii. | Pressure at foundation | : 10 tones / Sq.m |
| iv. | Probable safe bearing capacity of the foundation | : 20 tones / Sq.m |

2. **Superstructure:**

- | | | |
|-----|--|---|
| i. | Maximum stress in most critical Sections of masonry and concrete | a) R.C.C Concrete : 30 Kg / Sq.cm.
b) Masonry : 07 tones / Sq.m. |
| ii. | Nature of masonry and concrete And its safe permissible stress | : Brick masonry in cm: 30 tones / Sq.m.
R.C.C : 40 Kg / Sq.cm. |

The Structural of the building has been verified by me with reference to ISIS loading standards 875 (Latest version) and other relevant Indian Standard code of practices I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement. This Certificate does not include any Thatched sheds and also any flammable building material utility. Proper toilet facilities to be provided as per norms. If any thatched sheds are found at a later period after issue of this certificate / License this certificate gets invalid. A license may be granted for the period from 01.06.2022 to 31.05.2025.

Signature of the Correspondent

Signature of the Engineer

Er. D. NATARAJAN, B.E.(CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400, Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore-632 009
Cell. 94431 06470, 8056631312

மரம் வளர்ப்போம். மழை பெறுவோம்.

Er. D.NATARAJAN, B.E.(CIVIL),M.I.E.,
CHARTERED ENGINEER
REGISTERED & APPROVED ENGINEER
BY THE BOARD OF ENGINEERS, TAMIL NADU.
PANEL ENGINEER CLASS IA, VELLORE DISTRICT

Res: 50-A,3rd Street, S.S.Nagar. Palanipet,
Arakkonam – 631002
Off: 400, Nethaji Bose 4th Street
Phase III, TNHB, Sathuvachari
Vellore – 632 009
Cell: 9443106470, 8056631312
Email: dnatarajan8@gmail.com

FORM – C

STATEMENT ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

VANIYAMBADI GLOBAL SCHOOL, AMBURPET VILLAGE, VANIYAMBADI

Form of certificate of structural soundness under sub section (b) of section of 4 of the madras Public Buildings (Licensing Act 1963 Madras Act 13 of 1965 referred to in rule 4 of the Madras Public building (Licensing) rules 1977.

Certify that have inspected the building mentioned in the statement below and I have satisfied myself the building is structural sound to be used as a public building for the purpose note in the statement. The structural soundness of the building has been verified taking into account the loading as per latest Indian standard 875.

Location of the building door No. street name and name of the place	Age of the building	Value of the Building	No. of Storeys	Short Description of structure steel RCC framed or load bearing masonry
1.	2.	3.	4.	5.
VANIYAMBADI GLOBAL SCHOOL D. No. 231/11, Nethaji Nagar, Amburpet Village, Vaniyambadi Taluk, Tirupattur District - 635752	<u>New Block I:</u> GF: RCC: 10 Years FF: RCC: 07 Years <u>Toilet Block:</u> GF: RCC: 10 Years	Rs. 55.00 Lakhs	Ground Floor +1	RCC Framed Structure

Purpose for which the building is certified for use	The Period for which the building will be structurally sound	No of the persons to be accommodated	Remarks
6.	7.	8.	9.
Educational	License may be issued for the period of Three Years from 01.06.2022 to 31.05.2025.	580 Pupils only	Building is structurally sound

Signature of the Correspondent

Signature of the Engineer

Er. D. NATARAJAN, B.E.(CIVIL) MIE
Chartered Engineer
Panel Engineer Class 1A
Vellore District
400 Nethaji Bose 4th Street,
Phase III, TNHB, Sathuvachary
Vellore-632 009
Cell: 94431 06470, 8056631312

மரம் வளர்ப்போம், மழை பெறுவோம்.